

Office of the Principal
ADARSHA VIDYALAYA, RANGAPATHER

Rangapather, P.O. – Suffry

Dist. – Charaideo, Assam –785689 Ph. 9435158318/8761812216

Website: <http://www.mssvr.in> e-mail: modelschoolsivasagar@gmail.com

Affiliated to CBSE, Affiliation Code: 220009 School Code:-37188

Ref No.: MS/SVR/2021/ 1520

Date: 22-10-2021

To,

**The Station In. Charge
Fire Service Station
Charaideo, Sonari**

Sub: Application for issuing a Certificate of Fire Safety.

Sir/ Madam,

Most respectfully, I state you that we have been processing to apply for upgradation of affiliation to CBSE for opening new Class of 11 & 12 as per instruction of RMSA Assam. For this purpose we have to submit a certificate regarding Fire Safety that existed at our school.

Therefore, I would like to request you kindly to take necessary steps for issuing the same at your earliest convenience.

Name of School- Adarsh Vidyalaya, Rangapather.

Address: Vill: Rangapather, P.O- Suffry, Dist: Charaideo, Assam, Pin-785689

U-Dise Code: 18290500312

Affiliation Code: 220009

School Code:-37188

N.B- Proforma for the Fire Safety is enclosed herewith.

Yours faithfully



(Kumud Dihingia)

Principal

Adarsha Vidyalaya, Rangapather

dated 22nd October, 2021

Memo No: MS/SVR/2021/1520(A)

Copy to:

1. The Deputy Commissioner, Charaideo District cum Chairman, SMDC, Adarsha Vidyalaya Rangapather for kind information.
2. The Inspector of Schools, SDC Sivasagar for kind information.
3. Office File.

Sd/-

(Kumud Dihingia)

(Principal)

Adarsha Vidyalaya, Rangapather

GOVT. OF ASSAM
SONARI FIRE & EMERGENCY SERVICES STATION, CHARAIDEO, ASSAM

NO. SNR / F&ESS / 54 / 712 / 21

Dated the Sonari 23rd October 2021

To,

The Principal,
Adarsha Vidyalaya, Rangapather,
Dist. - Charaideo

Sub: INSPECTION REPORT AND CONDITIONS TO BE FULFILLED FOR IMPLEMENTATION OF FIRE PREVENTION AND FIRE SAFETY MEASURES AS WELL AS MEANS OF ESCAPE IN THE EXISTING G+1 STORIED EDUCATIONAL BUILDING OF "ADARSHA VIDYALAYA, RANGAPATHER" ON THE LAND BEARING DAG NO. 244, MOUZA - ABHAYPUR, LOCATED AT RANGAPATHER, DIST. CHARAIDEO

Sir,

With reference to the subject cited above, I would like to inform you that I have inspected the School building of "ADARSHA VIDYALAYA, RANGAPATHER" on dated 23.10.2021 AM.

The findings are as below -

Name of school	Details of Fire Extinguisher available		Present condition	Remarks
	Type	Quantity		
Adarsha Vidyalaya, Rangapather	DCP	5 (five) nos.	Unserviceable	One Fire Point is also available
	AFFF	1 (one) no.	Unserviceable	
	CO ₂	1 (one) no.	Serviceable	

You are requested to implement the additional Fire Prevention and Fire Safety measures as well as Means of Escape in the existing G+1 storied building of "ADARSHA VIDYALAYA, RANGAPATHER" mentioned above at the above noted location for safety of lives and properties as well as the building itself.

After proper implementation of the following Fire Safety measures, Fire Safety "No Objection Certificate" may be considered.

MINIMUM REQUIREMENT OF FIRE PROTECTION, FIRE PREVENTION MEASURES AND MEANS OF ESCAPE FOR THE G+1 STORIED BUILDING OF "ADARSHA VIDYALAYA, RANGAPATHER" AS PER 'NATIONAL BUILDING CODE OF INDIA' - 2016			
Sl. No.	FIRE PROTECTION MEASURES	Sl. No.	FIRE PREVENTION MEASURES & MEANS OF ESCAPE
1	<p>Fire Extinguishers :-</p> <p>a) Adequate nos. of ABC extinguisher of 6 kg capacity should be provided. The extinguishers are so distributed so that a person has to travel not more than 15 m to reach the nearest extinguisher.</p> <p>b) At least 2(two) nos. of CO₂ extinguisher of 4.5 kg capacity should be provided near the electric panel board/ main switch gear box.</p> <p>c) At least 2(two) nos. of AFFF extinguisher of 9 L. capacity should be provided near the DG set.</p> <p>d) At least 2(two) nos. of CO₂ extinguisher of 4.5 kg capacity should be provided</p> <p>N.B.:- All fire extinguishers should be newly introduced Indian Standard - as per IS:15683/2006.</p>	1	Lightning arrestor shall be provided to protect the building from lightning disaster.
		2	Electrical wiring should be of either conduit or concealed type.
		3	To eliminate fire hazards, good housekeeping both inside and outside of the building should be strictly maintained by the staff and management of the building.
		4	Employee/staff/students must be trained to operate the fire safety installations
		5	<p>FIRE DRILL & FIRE ORDER :</p> <p>Fire notices/ Orders prepared to fulfill the requirements of fire fighting and evacuation from the building in the event</p>

2	Adequate nos. of Hose Reel should be installed in each floors of the building. The length of Hose Reel should be such that no part of the floor remains unprotected when the hose reel is fully extended. The hose reel shall be connected directly to the down-comer main and diameter of the hose reel shall not be less than 19 mm.	of fire and other emergency. The staff/ security persons shall be made thoroughly conversant with their actions in the event of emergency, by displaying fire notice at vantage points and also through regular training. Such notices shall be displayed prominently in broad lettering.
3	Terrace water tank = 10,000 Litre (exclusively dedicated for fire fighting purpose)	6 Internal Staircase : 1. Width of Staircase = 1.5 metre 2. Minimum Width of Tread = 300 mm 3. Maximum Height of riser = 150 mm 4. Height of Handrails = 1000 mm 5. Maximum riser per flight = 15 nos. N.B. : Internal Stairs shall be constructed of non-combustible materials throughout. No Gas piping or electrical panels shall be allowed in the stairway. Ducting in stairway may be permitted if it is of 1 hour fire resistance rating.
4	Pump capacity = 450 Litre/min at the Terrace Tank level with minimum pressure of 2.0 kg/cm ² .	
5	Manually Operated Electric Fire Alarm system should be provided.	
6	Adequate nos. of Fire point provision consisting of 3(three) nos. of water buckets, 3(three) nos. of sand buckets and 1(one) no. of ceiling hook should be provided in front of the building.	
		7 Emergency telephone numbers should be displayed in suitable place that easily seen by the staff and common people.

Above action should be completed by 20th November' 2021 and submit compliance report to the undersigned from your end.

Yours faithfully

[Signature]
23/10/21
Station Officer
Sonari Fire & Emergency Services
Station, Charaideo

NO. SNR / F&ESS / 54 /

/ 21

Dated the Sonari

Copy to :-

1. The Spl. Director General of Police cum Director, Fire & Emergency Services, Assam, Guwahati for favour of your kind information.
2. The Deputy Commissioner, Charaideo for favour of your kind information.
3. The Inspector of Schools, Sivsagar for kind information.

[Signature]
Station Officer
Sonari Fire & Emergency Services
Station, Charaideo